



October 6, 2020

Mr. Andrew Weber
Superintendent
Mullica Township School District
500 Elwood Road
Elwood, New Jersey 08217

RE: Microbial Clearance Sampling
Mullica Township School
500 Elwood Road
Elwood, New Jersey 08037
Hillmann Project No.: PH-1328

Dear Mr. Weber:

Thank you for retaining Hillmann Consulting, LLC (Hillmann) to address your environmental concerns. Hillmann prepared a Scope of Work for microbial remediation within the Mullica Township School dated September 18, 2020. The Scope of Work identified areas that would be subject to professional remediation and areas that would be cleaned by District staff.

Hillmann proposed air sampling as the clearance criteria for the areas addressed by the remediation contractor. These areas are remediated utilizing full containment barriers and air scrubbing technology. As these areas constitute a sealed environment void of influence from outside air, air sampling clearance is the appropriate and industry-standard protocol for assessing the effectiveness of the remediation efforts.

Areas cleaned by the District staff were not scoped to be closed environments, but rather subject to typical cleaning efforts. No isolation barriers or air scrubbing technology was deemed necessary in these areas due to the small quantities of visible mold growth observed at the time of the scoping inspection. As such, air sampling as a clearance criterion is inappropriate and not aligned with industry standards as these areas are not isolated from other areas of the building and air sampling would not effectively measure spore concentrations within these areas.

If you have any questions, or need additional information, please feel free to contact our office at (856) 581-9055.

Regards,
HILLMANN CONSULTING, LLC

Rafael L. Torres, III
Director of Operations
Philadelphia Area Regional Office

Jill Asch, MPH, CIH, CSP
Corporate Health and Safety Officer

Your Property. Our Priority.
Making a better future for the communities we touch.
www.HillmannConsulting.com